

2022 Consumer Confidence Report for Public Water System CONCORD-ROBBINS WSC

TX 1450018

This is your water quality report for January 1 to December 31, 2022

For more information regarding this report contact:

Name: Travis Treadway

Phone 903-626-4330

Este reporte incluye informacin importante sobre el agua para tomar. Para asistencia en espanol favor de llamar al telefono (903) 626-4330.

Information about Source Water

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact Travis Treadway at 903-626-4330.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <https://www.tceq.texas.gov/gis/swaview>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <https://dww2.tceq.texas.gov/DWW/>

Source Water Name		Type of Water	Report Status	Location
1 – SH 7 CONCORD	10101 W. HWY 7	GW	Active	Carrizo Wilcox
2 – HITT 8	7003 PR 3425	GW	Active	Carrizo Wilcox
3 – HITT 5	7003 PR 3425	GW	Active	Carrizo Wilcox
4 – REMOTE 8	1040 CR 391	GW	Active	Queen City
5 – REMOTE 5	1040 CR 391	GW	Active	Queen City
6 – PLANT 3	2406 FM 1147	GW	Active	Simsboro
7 – PLANT 4	14296 W CR 344	GW	Active	Simsboro
8 – FLYNN	11083 FM 977 W	GW	Active	Carrizo Wilcox
LAKWOOD / FORMERLY G1420025A	20101 PR 3186	GW	Active	Carrizo Wilcox

INFORMATION ABOUT YOUR DRINKING WATER

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas productions, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum productions, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas productions and mining activities.

In order to ensure that tap water is safe to drink EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Water Drinking Hotline or at URL: <http://www.epa.gov/safewater/lead>.

Public Participation Opportunities

Date: 3rd Monday of Each Month
Time: 6:00 PM
Location: 9066 Hwy 7 W – Water Office
Phone Number: 903-626-4330

Definitions and Abbreviations

Definitions and Abbreviations	The following tables contain scientific terms and measures, some of which may require explanation.
Action Level:	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Action Level Goal (ALG):	The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacterial have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum Residual Disinfectant Level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL:	Million fibers per liter (a measure of asbestos)
Mrem:	Millirems per year (a measure of radiation absorbed by the body)
NA:	Not Applicable
NTU:	Nephelometric turbidity units (a measure of turbidity)
pCi/L	Picocuries per liter (a measure of radioactivity)
ppb:	Micrograms per liter or parts per billion – or one ounce in 7,350,000 gallons of water.
ppm:	Milligrams per liter or parts per million – or one ounce in 7,350 gallons of water.
ppq:	Parts per quadrillion, or picograms per liter (pg/L)
ppt:	Parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants Detected

LEAD AND COPPER

Definitions:

Active Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. AGLs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow:

☒

Lead and Copper	Date Sampled	MCLG	Action Level (ALG)	90 th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2021	1.3	1.3	0.057	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2021	0.015	0.015	0	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

2022 Water Quality Test Results

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2022	4	4.3-4.3	No goal for the total	60	ppb	N	By-products of drinking water disinfection.
Total Trihalomethanes (TTHM)	2022	26	26.2-26.2	No goal for the total	80	ppb	N	By-products of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2022	0.12	0.01-0.12	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	2022	3.6	2.1-3.6	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride	2022	0.158	0.047-0.158	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2022	0.0623	0.0229-0.0623	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/positron emitters	2022	4.1	4.1-4.1	0	50	pCi/L	N	Decay of natural and man-made deposits.

Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Di (2-ethylhexyl) Phthalate	2018	2.5	0 – 2.5	0	6	ppb	N	Discharge from rubber and chemical factories
Combined Radium 226/228	2022	1.5	1.5 – 1.5	0	5	pCi/L	N	Erosion of natural deposits
Volatile Organic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Carbon Tetrachloride	2022	1	0-0.51	0	5	Ppb	N	Discharge from petroleum refineries.
Xylenes	2022	0.00194	0-0.00194	10	10	ppm	N	Discharge from petroleum factories; Discharge from chemical factories

COLIFORM BACTERIA

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest Number of Positive	Fecal Coliform of E Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample	1	0	0	N	Naturally present in the environment

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Violation Y/N	Likely Source of Contamination
2022	Chlorine (Free)	1.06	0.42	1.83	4.0	1.0	ppm	N	Water Additive Used in Control Microbes